OSM/UWWTR LUT Exceedance PART A

Permit Number	AWCNF809C/11022D
Name of Operator	Anglian Water Services
Location	Thurleigh WRC

(b) Notification requirements for the breach of a limit specified in schedule 3 table S3.1 (including individual exceedances of limits which are covered by condition 3.1.5) To be notified as soon as practicable following detection by a reporting system and format specified by the Environment Agency		
Self-monitoring regime	OSM	
Type of failure	LUT	
Date of sample event	16/06/2022	
Date result sent from Lab to SDS	20/06/2022	
Determinand	Ammonia	
Result and units	8.94 mg/l	
Limit and units	8 mg/l	
Comments on result	Under investigation	
Comments on delay from lab		
to scientist		
(if longer than 10 working days)		

EPR Permit	No

Anglian Region anglianosmfailures@environment-agency.gov.uk

Thames Region

thamesosm.returns@environment-agency.gov.uk

Midlands Region

@environment-agency.gov.uk