

OSM/UWWTR LUT Exceedance

PART A

Permit Number	AWCNF809C/11022D
Name of Operator	Anglian Water Services
Location	Thurleigh WRC

(b) Notification requirements for the breach of a limit specified in schedule 3 table S3.1 (including individual exceedances of limits which are covered by condition 3.1.5)	
To be notified as soon as practicable following detection by a reporting system and format specified by the Environment Agency	
Self-monitoring regime	OSM
Type of failure	LUT
Date of sample event	16/06/2022
Date result sent from Lab to SDS	23/06/2022
Determinand	BOD
Result and units	19.1 mg/l
Limit and units	15 mg/l
Comments on result	Under investigation
Comments on delay from lab to scientist (if longer than 10 working days)	

EPR Permit	No
------------	----

Anglian Region

anglianosmfailures@environment-agency.gov.uk

Thames Region

thamesosm.returns@environment-agency.gov.uk

Midlands Region

██████████@environment-agency.gov.uk